



**CITY OF NAPERVILLE**  
**HOMEOWNER NOTIFICATION FORM**  
***BUILDING CODE SMOKE DETECTOR & CARBON MONOXIDE DETECTORS***

*This form serves as notification to all homeowners and contractors of the building code requirement for the smoke detectors & monoxide detectors to current building code standards. The City of Naperville has adopted the 2018 IRC with local amendments, Section R314 & R315.*

- When a room addition or interior remodeling that requires a permit occurs the entire building shall be provided with smoke detectors as required for new dwellings:
- All smoke detectors shall be interconnected such that the actuation of one alarm will actuate all the alarms in the individual unit.
- All detectors shall be approved and listed and shall be installed in accordance with the manufacturer's specifications.
- Smoke detectors shall be installed in each sleeping room, outside of each separate sleeping area within 15' of each bedroom and on each additional story of the dwelling, including basements and cellars but not including crawl spaces and uninhabitable attics.
- In portions of the residence that are impacted by the renovation or addition, smoke detectors shall be 110V, interconnected with a battery backup (wiring shall be permanent and without a disconnecting switch other than those required for overcurrent protection); smoke detectors required in the portion of the residence that is not impacted by the renovation or additional shall be permitted to be battery powered and interconnected.
- Where work inside a dwelling requires a permit, a carbon monoxide detector(s) must be installed outside and within 15' of each sleeping room or area. In portions of the residence that are impacted by the renovation or addition, carbon monoxide detectors shall be 110V, interconnected with a battery backup; carbon monoxide detectors required in the portion of the residence that is not impacted by the renovation or additional shall be permitted to be battery powered and interconnected.

*I have read the above building code requirements and fully understand that all smoke detector & carbon monoxide requirements must be met in order to pass **both the rough electric and final inspections** on my room addition or alteration permit:*

Homeowner's Address: \_\_\_\_\_

Homeowner's Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Contractor's Signature: \_\_\_\_\_ Date: \_\_\_\_\_